Report Date: 9/14/2022 Report Time: 4:11 PM EDT

Region I Hotline Log Entry Information

Data ID: 186781

Date Of Report: 3/2/2006 NRC #: 789639 **State** #: 2006-01198 ERNS #: 192033

Material Type: Oil Receiver: OSC Sims

Material / Amount: OIL, FUEL: NO. 6 (5000 GALLON(S))

Location: Street:

City: NEW HAVEN County: NEW HAVEN

State: CT Latitude: Longitude:

Source of Pollution: PSEG-CONNECTICUT

Water Body: N/A
State Or EPA Responded: DEP

Initial EPA Action: Coord w/DEP and USCG

Status: URL:

Associated Action Reports

DataID: 0076170

Date: 3/2/2006 Time: 15:02 EST

Duty Officer/Responder Name: NRC Report #: 789639 Hotline Log DataID: 186781

Action Information

Description: Telephone call with S.Kruse indicates no impact offsite/to water. Spill confined to containment area at facility. Cause of spill

attributed to pump failure. COTP notfied of incident by facility. CTDEP onscene and monitoring cleanup.

Follup-Up:

Person Contacted

Name: Sally Kruse
Organization: PSEG
Phone #: (203)9745055

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 789639

INCIDENT DESCRIPTION

*Report taken by: CIV KEVIN WILLIAMS at 12:45 on 02-MAR-06

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area:

The incident occurred on 02-MAR-06 at 07:00 local time.

Affected Medium: OTHER INTO A CONTAINMENT AREA

REPORTING PARTY

Name: SALLY KRUSE

Organization: PSEG-CONNECTICUT

Address: NEW HAVEN HARBOR STATION

NEW HAVEN, CT 06512

PSEG-CONNECTICUT called for the responsible party.

PRIMARY Phone: (203) 9745055

INCIDENT LOCATION

NEW HAVEN HARBOR STATION County: NEW HAVEN

City: NEW HAVEN State: CT Zip: 06512

RELEASED MATERIAL(S)

CHRIS Code: OSX Official Material Name: OIL, FUEL: NO. 6

Also Known As:

Qty Released: 5000 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER STATED THERE WAS A RELEASE OF MATERIALS FROM A PUMP HOUSE DUE TO AN EQUIPMENT FAILURE.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: POWER PLANT Power Generating Facility: YES Generating Capacity: 465 MEGA WATTS

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

Empl/Crew: NO INJURIES: Hospitalized: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages:

Hours Direction of Closure

Closure Type Description of Closure Closed

N

Major Art Road: N

Waterway: N Track:

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material: NO

REPORTING PARTY

Type of Organization: PRIVATE ENTERPRISE

SUSPECTED RESPONSIBLE PARTY

SALLY KRUSE Organization: PSEG-CONNECTICUT

NEW HAVEN HARBOR STATION

NEW HAVEN, CT 06512

PRIMARY Phone: (203) 9745055

Type of Organization: PRIVATE ENTERPRISE

REMEDIAL ACTIONS

THE MATERIALS ARE BEING VACUUMED OUT AND THEN THE SURFACE WILL BE WASHED OUT BY A

CONTRACTOR.

Release Secured: YES

Release Rate:

Estimated Release Duration:

WEATHER

Weather: OVERCAST, 28@F

ADDITIONAL AGENCIES NOTIFIED

Federal: NONE

State/Local: DEP, FIRE DEPARTMNT., CAPT OF PORT.

State/Local On Scene: FIRE DEPARTMENT 2006-01198 State Agency Number:

NOTIFICATIONS BY NRC

DOT CRISIS MANAGEMENT CENTER (PRIMARY)

02-MAR-06 12:51 (202)3661863

EPA CRIMINAL INVEST DIV REGION 1 (PRIMARY)

02-MAR-06 12:51 (617)9182310

MSO LONG ISLAND SOUND (PRIMARY)

02-MAR-06 13:28 (203)4684444 OLSEN

NATIONAL INFRASTRUCTURE COORD CTR (PRIMARY)

02-MAR-06 12:51 (202)2829201

NOAA RPTS FOR CT (PRIMARY)

02-MAR-06 12:51 (206)5266344

CTDEP OIL & CHEM SPILL RESP DIV (PRIMARY)

02-MAR-06 12:51 (860)4243338

ADDITIONAL INFORMATION

NO ADDITIONAL INFORMATION.

*** END INCIDENT REPORT # 789639 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil